



KEY

— E(UGHV)	PROPOSED UNDERGROUND SPEN LV CABLE
— E(UGLV)	PROPOSED UNDERGROUND PRIVATE LV CABLE
■	PROPOSED PLANT ROOM

- NOTES**
1. ALL CABLES TO BE INSTALLED WITH MINIMUM 910mm DEPTH OF COVER WITH APPROVED MARKER TAPE INSTALLED 200mm AND 250mm ABOVE LV AND HV CABLES, RESPECTIVELY.
 2. PLANT ROOM TO BE CONSTRUCTED WITHIN EXISTING SLOPED GROUND.
 3. PLANT ROOM TO HOUSE ELECTRIC SWITCHGEAR AND GROUND SOURCE HEATING PUMP.

REPRODUCED FROM OS MASTERMAP 1:2500 SCALE BY PERMISSION OF ORDNANCE SURVEY ON BEHALF OF THE CONTROLLER OF HER MAJESTY'S STATIONERY OFFICE. © CROWN COPYRIGHT. ALL RIGHTS RESERVED. LICENCE NUMBER 100043718.	SCHEME MYNYDD TY MAWR	SKETCH TITLE PROPOSED ELECTRICITY CABLE SUPPLY ROUTE	DRAWING BY. G AP GWYNDAF DATE 20/07/2021
			DRAWING NO. 0013-01